



# PRODUCT PERFORMANCE RATING

**Document ID 091320190039-9571387**

Issued on 13 September 2019

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 14.12.005**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Variable refrigerant flow / Débit de réfrigérant variable (VRF)
Product type	VRF / Air cooled/ Reversible
Brand	LG
Range	MULTI V 5
Product référence	ARUM200LTE5

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
LG Electronics		Benelux	Netherlands

FEATURE	VALUE	UNIT
<b>COOLING</b>		
Pc out	56.00	kW
Pec out	12.76	kW
EERout	4.39	



# PRODUCT PERFORMANCE RATING

Document ID 091320190039-9571387

Issued on 13 September 2019

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 14.12.005**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING</b>		
Ph out	56.00	kW
Peh out	12.20	kW
COPout	4.59	

FEATURE	VALUE	UNIT
<b>ACOUSTICS</b>		
LwO env	93.00	dB(A)

FEATURE	VALUE	UNIT
<b>ACOUSTICS IN HEATING</b>		
LwO env in heating	96.00	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 091320190039-9571387

Issued on 13 September 2019

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 14.12.005**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>SEASONALCOOLING</b>		
SEER	8.05	
$\eta_{sc}$	319.00	%

FEATURE	VALUE	UNIT
<b>COOLING PL COND B</b>		
PcB	41.30	kW
EERB	6.00	

FEATURE	VALUE	UNIT
<b>COOLING PL COND C</b>		
PcC	26.50	kW
EERC	7.85	



# PRODUCT PERFORMANCE RATING

Document ID 091320190039-9571387

Issued on 13 September 2019

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 14.12.005**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>COOLING PL COND D</b>		
PcD	11.80	kW
EERD	17.00	

FEATURE	VALUE	UNIT
<b>SEASONALHEATING</b>		
Pdesignh	44.10	kW
SCOP	3.98	
$\eta_{sh}$	156.20	%

FEATURE	VALUE	UNIT
<b>HEATING PL COND A</b>		
PhA	38.80	kW
COPA	2.80	



# PRODUCT PERFORMANCE RATING

Document ID 091320190039-9571387

Issued on 13 September 2019

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 14.12.005**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING PL COND B</b>		
PhB	23.60	kW
COPB	3.30	

FEATURE	VALUE	UNIT
<b>HEATING PL COND C</b>		
PhC	15.20	kW
COPC	6.20	

FEATURE	VALUE	UNIT
<b>HEATING PL COND D</b>		
PhD	6.75	kW
COPD	8.90	



# PRODUCT PERFORMANCE RATING

Document ID 091320190039-9571387

Issued on 13 September 2019

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 14.12.005**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>T BIVALENT</b>		
Tbiv	-10.00	°C
PhTbiv	43.90	kW
COPTbiv	2.40	

FEATURE	VALUE	UNIT
<b>PSBC</b>		
Psbc	40.00	W

FEATURE	VALUE	UNIT
<b>PSBH</b>		
Psbh	215.00	W



# PRODUCT PERFORMANCE RATING

**Document ID 091320190039-9571387**

Issued on 13 September 2019

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 14.12.005**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>GENERAL - PRODUCT</b>		
Mounting	ducted	
Cassette Type		
IU Range Names	ARNU***B***	
Main Power Supply	400-3-50	
Refrigerant	R410A	
Capacity Control	Variable	